

PERMITTEE NAME/ADDRESS: (include Facility Name/Location if different)
 NAME: NAMPA, CITY OF
 ADDRESS: WASTEWATER TREATMENT PLANT
 340 WEST RAILROAD STREET
 LOCATION: NAMPA, ID 83687-1741

FACILITY: WASTEWATER TREATMENT PLANT

LOCATION: NAMPA, ID 83687-1741
 ATTN: ANDREW ZIMMERMAN, WWTP SUPT

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 ID0022063
 PERMIT NUMBER
 001 A
 DISCHARGE NUMBER
 F - FINAL

MONITORING PERIOD
 YEAR | MO | DAY | YEAR | MO | DAY
 FROM 16 | 10 | 01 TO 16 | 10 | 31

*** Check here if No Discharge ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	(3 Card Only) (46-53)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (54-61)			NO. OF EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MAXIMUM				
TEMPERATURE, WATER DEG.CENTIGRADE 00010 1 0 0	*****	*****	****	*****	19.3	(04)	20.7	(04)	0	02/SH	GRAB	
EFFLUENT GROSS VALUE	*****	*****	****	*****	REPORT MO AVG	DEG.C	REPORT DAILY MX	DEG.C	0	WEEKLY	GRAB	
OXYGEN, DISSOLVED PERCENT SATURATION 00301 1 0 1	*****	*****	****	*****	96	(23)	94	(23)	0	02/SH	GRAB	
EFFLUENT GROSS VALUE	*****	*****	****	*****	90	PERCENT	80	PERCENT	0	WEEKLY	GRAB	
BOD, 5-DAY (20 DEG. C) 00310 G 0 0	20,198	*****	(26)	*****	250	(19)	*****	(19)	0	1/1	COMP 24	
RAW SEW / INFLUENT	REPORT MO AVG	*****	LBS / DY	*****	REPORT MO AVG	MG / L	*****	MG / L	0	WEEKLY	COMP 24	
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	724	953	(26)	*****	8	(19)	11	(19)	0	25/30	COMP 24	
EFFLUENT GROSS VALUE	3000 MO AVG	4500 WKLY AVG	LBS / DY	*****	30 MO AVG	MG / L	45 WKLY AVG	MG / L	0	WEEKLY	COMP 24	
PH	*****	*****	*****	*****	7.3	(12)	7.5	(12)	0	1/1	GRAB	
00400 1 0 0	*****	*****	*****	*****	6.5	SU	9.0	SU	0	WEEK - DAYS	GRAB	
EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	MAXIMUM	*****	MAXIMUM	0	1/1	COMP 24	
SOLIDS, TOTAL SUSPENDED 00530 G 0 0	19,543	*****	(26)	*****	242	(19)	*****	(19)	0	1/1	COMP 24	
RAW SEW / INFLUENT	REPORT MO AVG	*****	LBS / DY	*****	REPORT MO AVE	MG / L	*****	MG / L	0	WEEKLY	COMP 24	
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	1,052	1,276	(26)	*****	11	(19)	14	(19)	0	1/1	COMP 24	
EFFLUENT GROSS VALUE	3000 MO AVG	4500 WKLY AVG	LBS / DY	*****	30 MO AVG	MG / L	45 WKLY AVG	MG / L	0	WEEKLY	COMP 24	
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	<p>SHANNON JOHNSON, WWTP AST. SUPT.</p> <p>TYPED OR PRINTED</p>											
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)	<p>THIS REPORT IS THE PROPERTY OF THE U.S. ENVIRONMENTAL PROTECTION AGENCY. IT IS LOANED TO YOUR AGENCY/ORGANIZATION AND IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF THE U.S. ENVIRONMENTAL PROTECTION AGENCY. USE OF THIS REPORT IS LIMITED TO THE SPECIFIC PROJECT AND LOCATION FOR WHICH IT WAS PREPARED. THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF THE U.S. ENVIRONMENTAL PROTECTION AGENCY AND IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF THE U.S. ENVIRONMENTAL PROTECTION AGENCY.</p>											
TELEPHONE	208-468-5840											
DATE	16 11 18											
OFFICER OR AUTHORIZED AGENT	<p>SHANNON JOHNSON, WWTP AST. SUPT.</p> <p>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER</p>											
YEAR MO DAY	16 11 18											

PERMITTEE NAME/ADDRESS: (include Facility Name/Location if different)

NAME: NAMPA, CITY OF
 ADDRESS: WASTEWATER TREATMENT PLANT
 340 WEST RAILROAD STREET
 LOCATION: NAMPA, ID 83687-1741

FACILITY: WASTEWATER TREATMENT PLANT

LOCATION: NAMPA, ID 83687-1741
 ATTN: ANDREW ZIMMERMAN, WWTP SUPT

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

PERMIT NUMBER: ID0022063
 DISCHARGE NUMBER: 001 A

MAJOR (SUBR 02) F - FINAL

MONITORING PERIOD
 FROM 16 | 10 | 01 TO 16 | 10 | 31
 YEAR | MO | DAY

Check here if No Discharge

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	QUANTITY OR LOADING (54-61)			QUALITY OR CONCENTRATION (54-61)			UNITS	EX NO. (62-63)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (69-70)	
	AVERAGE (46-53)	MAXIMUM (46-53)	UNITS (26-27)	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)					
NITROGEN, AMMONIA TOTAL (AS N) 00610 0 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	4.2	5.7	(26)	*****	0.05	0.06	(19)	0	22/30	COMP 24
	PERMIT REQUIREMENT	86.3 MO AVG	196.2 DAILY MX	LBS / DY	*****	0.9 MO AVG	2.0 DAILY MX	MG / L		WEEKLY	COMP 24
NITROGEN, AMMONIA TOTAL (AS N) 00610 P 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	4.5	6.9	(26)	*****	0.05	0.07	(19)	0	9/30	COMP 24
	PERMIT REQUIREMENT	98.1 MO AVG	225.5 DAILY MX	LBS / DY	*****	1.0 MO AVG	2.3 DAILY MX	MG / L		WEEKLY	COMP 24
NITROGEN, AMMONIA TOTAL (AS N) 00610 Q 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	NA	NA	(26)	*****	NA	NA	(19)	NA	NA	COMP 24
	PERMIT REQUIREMENT	117.7 MO AVG	274.6 DAILY MX	LBS / DY	*****	1.2 MO AVG	2.8 DAILY MX	MG / L		WEEKLY	COMP 24
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	NA	NA	(26)	*****	NA	NA	(19)	NA	NA	COMP 24
	PERMIT REQUIREMENT	76.5 MO AVG	176.52 DAILY MX	LBS / DY	*****	0.8 MO AVG	1.8 WKLY AVG	MG / L		WEEKLY	COMP 24
COLIFORM, FECAL MF, M - FC BROTH, 44.5 C 31616 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	29	55	(13)	0	1/1	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	200 WKLY GEO	800 DAILY MX	#/ 100 ML		WEEK - DAYS	GRAB
E. COLI, SM9223, Colifert 31648 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	27.0	(13)	0	1/7	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	REPORT MO GEO	#/ 100 ML		ONCE / MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	11.2	*****	(03)	*****	*****	*****	*****	0	CONTINUOUS	RCORDR
	PERMIT REQUIREMENT	MO AVG	*****	MGD	*****	*****	*****	*****		CONTINUOUS	RCORDR
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER											
SHANNON JOHNSON, WWTP AST. SUPT.											
TYPED OR PRINTED											
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER											
OFFICER OR AUTHORIZED AGENT											
TELEPHONE											
NUMBER											
YEAR MO DAY											
DATE											

I CERTIFY UNDER PENALTY OF LAW THAT THE DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER THE DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY KNOWLEDGE OF THE PERSON OR PERSONS WHO PREPARED THE INFORMATION, I AM DIRECTLY RESPONSIBLE FOR OBTAINING THE INFORMATION, THE INFORMATION SUBMITTED IS TO THE BEST OF MY KNOWLEDGE TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1911. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Date	Flow MGD	NAMPA WASTEWATER DIVISION												EFFLUENT					PERCENT REMOVAL					SHEET 1									
		BOD mg/L	COD mg/L	TSS mg/L	NH3-N mg/L	TKN mg/L	pH	BOD lbs/day	TSS lbs/day	NH3-N lbs/day	TKN lbs/day	D.O. mg/L	Temp °C	FOG mg/L	Ortho P mg/L	Total P lbs	Effluent Flow MGD	BOD mg/L	TSS mg/L	NH3-N mg/L	TKN mg/L	pH	BOD lbs/day	TSS lbs/day	NH3-N lbs/day	TKN lbs/day	%	%	%	Ortho P mg/L	Total P mg/L	Total P lbs	
1	10.448	220	625	208	20.6	30.5	7.5	19172	18126	1795	2658				4.10	357	11.901	6	7	0.07	6.9	695	695	6.9	96.9	96.2	95.6	1.10	109				
2	10.681	250	555	245	19.7	30.5	7.8	22270	21824	1755	2717				4.50	401	12.172	7	7	0.04	4.1	711	711	4.1	96.8	96.7	99.8	0.73	74				
3	10.545	215	480	203	21.8	31.0	8.0	18908	17853	1917	2726				2.00	176	12.176	7	6	0.05	5.1	609	609	5.1	96.2	96.6	99.7	0.95	96				
4	10.486	230	495	220	20.2	30.0	7.8	20114	19240	1767	2824				4.70	411	11.783	6	9	0.04	3.9	590	884	3.9	97.1	95.4	99.8	0.95	93				
5	10.238	205	490	218	21.5	29.7	7.7	17506	18701	1836	2536				4.40	376	11.521	8	8	0.04	1.57	769	769	3.8	95.6	95.9	99.8	0.90	86				
6	10.108	230	535	231	21.5	32.9	7.7	19369	19473	1812	2773				4.70	395	11.534	6	8	0.06	5.8	577	770	5.8	97.0	96.0	99.7	0.80	77				
7	9.984	215	515	217	22.3	31.6	8.0	17961	18148	1865	2643				4.70	393	11.277	8	12	0.03	1.94	752	1129	2.8	95.8	93.8	99.8	1.05	99				
8	10.028	215	475	228	25.8	32.4	7.8	17572	18635	2109	2648	4.10	20.9		4.70	384	11.209	7	8	0.04	3.7	654	748	3.7	96.3	96.0	99.8	0.60	56				
9	8.806	215	465	239	26.6	30.8	7.8	17424	19389	2156	2496				4.70	381	11.102	6	10	0.05	7.5	556	926	4.6	96.8	95.2	99.8	1.90	176				
10	9.717	220	485	211	19.0	30.4	7.9	17790	17082	1536	2458				4.50	364	11.093	7	10	0.03	2.8	648	925	2.8	96.4	94.6	99.8	3.35	310				
11	9.696	240	570	227	21.5	37.3	7.9	19155	18118	1716	2977				4.80	383	11.088	6	7	0.04	7.3	554	647	3.7	97.1	96.4	99.8	3.15	291				
12	9.570	255	640	221	21.7	34.8	7.9	20087	17408	1709	2725				2.50	386	11.107	7	8	0.05	4.6	648	741	4.6	96.8	95.7	99.7	1.50	167				
13	9.445	240	530	211	20.9	35.1	7.9	18317	18103	1595	2679				4.70	369	11.108	4	9	0.05	7.4	371	834	4.6	98.0	94.8	99.7	1.85	171				
14	9.131	265	550	217	21.9	33.6	7.9	20826	17054	1721	2841				4.70	369	10.947	7	10	0.04	5.01	639	913	3.7	96.9	94.6	99.8	1.40	128				
15	9.423	235	520	225	29.2	35.3	7.8	18939	18133	2353	2845	4.15	21.1		4.70	379	11.144	5	12	0.04	7.5	465	1115	3.7	97.5	93.8	99.8	1.05	96				
16	9.663	285	505	194	25.2	35.9	7.8	16394	15515	2015	2871				4.50	360	11.378	8	10	0.04	7.5	759	949	3.8	95.4	93.9	99.8	2.05	195				
17	9.589	245	525	212	23.2	35.1	7.6	19653	17179	1880	2644				4.50	365	11.354	7	11	0.04	7.4	663	1842	3.8	96.7	93.9	99.8	1.90	180				
18	9.716	255	585	268	23.5	39.3	7.9	20333	21370	1874	3134				5.10	407	10.304	9	13	0.04	7.4	773	1117	3.4	96.2	94.8	99.8	2.90	249				
19	9.561	250	605	255	23.1	37.6	7.9	20260	20685	1872	3847				4.80	369	10.823	7	8	0.05	2.57	741	825	2.7	92.1	99.9	92.4	0.25	208				
20	9.717	295	640	238	23.0	38.7	7.8	23279	18781	1815	3954				4.90	387	10.990	18	18	0.04	7.4	1651	1625	2.7	91.2	99.8	91.5	2.30	208				
21	9.462	295	610	255	24.6	37.8	7.8	23825	20336	1962	3014				4.90	387	10.950	16	16	0.06	2.85	3.7	1651	1625	2.7	92.9	99.7	91.5	1.70	156			
22	9.562	280	655	330	24.5	40.1	7.8	22397	26396	1960	3208				5.00	399	10.754	16	16	0.06	7.3	1435	1435	5.4	92.9	99.9	91.5	0.95	85				
23	9.591	260	595	257	23.0	38.7	7.7	21140	20896	1870	3147				8.60	688	10.820	14	14	0.03	7.4	1263	1263	2.7	95.2	99.9	91.5	0.75	68				
24	9.749	240	545	248	23.2	38.3	8.0	19073	19709	1644	3044				4.40	358	11.181	15	15	0.06	7.5	1399	1399	5.6	93.3	99.7	91.5	1.90	177				
25	9.529	265	645	274	23.9	38.1	7.9	20740	21444	1870	2962				4.80	381	11.338	16	16	0.06	7.5	1513	1513	5.7	92.3	99.7	91.5	1.20	113				
26	9.384	290	610	269	24.2	39.0	7.9	22701	21057	1894	3053				5.10	399	11.358	11	14	0.06	7.4	1042	1326	5.7	95.0	93.8	99.7	2.00	189				
27	9.388	310	625	269	24.0	38.1	7.7	23801	20653	1843	2925				4.30	337	11.294	12	11	0.06	2.56	1130	1036	5.7	95.0	95.1	99.7	2.38	224				
28	8.266	295	590	277	23.1	35.7	7.9	22937	21538	1796	2776				4.60	360	11.223	11	11	0.06	7.4	1030	1030	5.6	95.7	95.0	99.7	1.50	140				
29	9.323	280	585	284	21.0	39.2	7.6	21771	22082	1633	3048				4.70	361	10.932	11	17	0.06	2.45	1003	1550	5.5	95.6	92.8	99.7	0.80	73				
30	9.623	275	600	262	23.2	37.3	7.7	22070	21027	1862	2894				5.10	397	11.119	7	12	0.04	7.4	679	1163	3.7	96.9	94.7	99.8	1.40	130				
31	9.230	265	550	285	24.8	38.9	7.7	20399	21939	1894	2994				4.60	369	11.625	10	12	0.04	7.4	812	974	3.9	96.3	95.4	99.8	2.35	228				
TOT	307.613							626124	605034	57526	82880				4.90	377	9.732	12	14	0.04	2.72	974	1136	3.2	95.2	94.0	99.8	2.90	235				
MIN	9.151	205	465	194	19.0	29.7	7.5	16394	15515	1536	2458				11078	347.387						18104	32624	134	2001				4683	TOT			
MAX	10.681	310	655	330	29.2	40.1	8.0	23801	26396	2353	3208				2.00	176	9.732	4	6	0.03	1.57	371	609	2.7	151				95.0	91.2	99.6	0.25	56
AVE	9.729	250	561	242	23.0	35.3	7.7	20190	19543	1856	2848				8.60	688	12.176	12	18	0.07	5.01	1130	1651	6.9	457				98.0	96.7	99.9	1.80	310
WVK	10.315	224	528	220	21.1	30.9	7.5	19334	19032	1821	2668				4.75	393	11.206	8	11	0.05	2.72	724	1052	4.3	250				96.4	94.6	99.8	1.04	151
WVK	9.543	238	531	222	22.5	33.5	7.5	18739	17678	1792	2661				359	11.697	7	8	0.05	1.76	672	795	4.6	167				96.5	95.8	99.7	93.6	91	
WVK	9.610	254	570	235	24.5	37.1	7.7	20369	18854	1967	2973				380	11.083	6	9	0.04	3.90	581	619	4.0	358				96.9	95.3	99.8	86.6	186	
WVK	9.447	276	600	276	23.5	38.3	7.7	21703	21674	1847	3017				383	10.919	7	14	0.04	2.71	665	1276	3.8	244				96.4	93.2	99.8	92.0	167	
															403	11.089	11	14	0.05	2.51	953	1239	4.7	232				95.7	94.2	99.7	92.0	158	

* From 10-19-2016 to 10-24-2016 all BOD effluent dilutions analyzed over depleted, therefore no concentrations could be calculated. Diffuser broke, switched basins as soon as construction allowed.

DMR NH3 and Chlorine Effluent Limits

Date	Creek Flow CFS	NH Limit conc (mg/L) /// lbs (lbs/day)	EFF N mg/L	EFF N lbs	***** *****	CI Limit conc (mg/L) /// lbs (lbs/day)	EFF CI ug/L	EFF CI lbs	Effluent Flow MGD	***** *****
1	60	2.3 mg/L /// 225.5 lbs/day	0.07	6.9	*****	16.8 ug/L /// 1.6 lbs/day	30	2.98	11.901	*****
2	63	2.3 mg/L /// 225.5 lbs/day	0.04	4.1	*****	16.8 ug/L /// 1.6 lbs/day	30	3.05	12.172	*****
3	65	2.3 mg/L /// 225.5 lbs/day	0.05	5.1	*****	16.8 ug/L /// 1.6 lbs/day	30	3.05	12.176	*****
4	66	2.3 mg/L /// 225.5 lbs/day	0.04	3.9	*****	16.8 ug/L /// 1.6 lbs/day	30	2.95	11.783	*****
5	66	2.3 mg/L /// 225.5 lbs/day	0.04	3.8	*****	16.8 ug/L /// 1.6 lbs/day	30	2.88	11.521	*****
6	67	2.3 mg/L /// 225.5 lbs/day	0.06	5.8	*****	16.8 ug/L /// 1.6 lbs/day	30	2.89	11.534	*****
7	68	2.3 mg/L /// 225.5 lbs/day	0.03	2.8	*****	16.8 ug/L /// 1.6 lbs/day	20	1.87	11.277	*****
8	70	2.3 mg/L /// 225.5 lbs/day	0.04	3.7	*****	16.8 ug/L /// 1.6 lbs/day	30	2.78	11.209	*****
9	43	2.3 mg/L /// 225.5 lbs/day	0.05	4.6	*****	16.8 ug/L /// 1.6 lbs/day	40	3.70	11.102	*****
10	32	2.0 mg/L /// 196.2 lbs/day	0.03	2.8	*****	13.4 ug/L /// 1.3 lbs/day	40	3.70	11.093	*****
11	30	2.0 mg/L /// 196.2 lbs/day	0.04	3.7	*****	13.4 ug/L /// 1.3 lbs/day	40	3.71	11.080	*****
12	29	2.0 mg/L /// 196.2 lbs/day	0.05	4.6	*****	13.4 ug/L /// 1.3 lbs/day	40	3.71	11.107	*****
13	29	2.0 mg/L /// 196.2 lbs/day	0.05	4.6	*****	13.4 ug/L /// 1.3 lbs/day	40	3.65	11.108	*****
14	30	2.0 mg/L /// 196.2 lbs/day	0.04	3.7	*****	13.4 ug/L /// 1.3 lbs/day	40	3.72	10.947	*****
15	31	2.0 mg/L /// 196.2 lbs/day	0.04	3.7	*****	13.4 ug/L /// 1.3 lbs/day	40	3.80	11.144	*****
16	32	2.0 mg/L /// 196.2 lbs/day	0.04	3.7	*****	13.4 ug/L /// 1.3 lbs/day	40	3.79	11.378	*****
17	31	2.0 mg/L /// 196.2 lbs/day	0.04	3.8	*****	13.4 ug/L /// 1.3 lbs/day	40	3.44	11.354	*****
18	32	2.0 mg/L /// 196.2 lbs/day	0.04	3.8	*****	13.4 ug/L /// 1.3 lbs/day	40	3.61	10.304	*****
19	32	2.0 mg/L /// 196.2 lbs/day	0.03	2.7	*****	13.4 ug/L /// 1.3 lbs/day	30	2.75	10.823	*****
20	31	2.0 mg/L /// 196.2 lbs/day	0.04	3.7	*****	13.4 ug/L /// 1.3 lbs/day	30	2.69	10.998	*****
21	32	2.0 mg/L /// 196.2 lbs/day	0.06	5.4	*****	13.4 ug/L /// 1.3 lbs/day	40	3.61	10.754	*****
22	33	2.0 mg/L /// 196.2 lbs/day	0.03	2.7	*****	13.4 ug/L /// 1.3 lbs/day	40	3.73	10.820	*****
23	33	2.0 mg/L /// 196.2 lbs/day	0.06	5.6	*****	13.4 ug/L /// 1.3 lbs/day	40	3.78	11.181	*****
24	32	2.0 mg/L /// 196.2 lbs/day	0.06	5.7	*****	13.4 ug/L /// 1.3 lbs/day	20	1.89	11.338	*****
25	33	2.0 mg/L /// 196.2 lbs/day	0.06	5.7	*****	13.4 ug/L /// 1.3 lbs/day	30	2.83	11.358	*****
26	33	2.0 mg/L /// 196.2 lbs/day	0.06	5.7	*****	13.4 ug/L /// 1.3 lbs/day	30	2.81	11.294	*****
27	33	2.0 mg/L /// 196.2 lbs/day	0.06	5.6	*****	13.4 ug/L /// 1.3 lbs/day	20	1.82	11.223	*****
28	33	2.0 mg/L /// 196.2 lbs/day	0.06	5.5	*****	13.4 ug/L /// 1.3 lbs/day	30	2.78	10.932	*****
29	33	2.0 mg/L /// 196.2 lbs/day	0.04	3.7	*****	13.4 ug/L /// 1.3 lbs/day	30	2.78	11.119	*****
30	33	2.0 mg/L /// 196.2 lbs/day	0.04	3.9	*****	13.4 ug/L /// 1.3 lbs/day	30	2.91	11.625	*****
31	32	2.0 mg/L /// 196.2 lbs/day	0.04	3.2	*****	13.4 ug/L /// 1.3 lbs/day	20	1.62	9.732	*****
AVERAGE	41	1.0 mg/L /// 98.1 lbs/day	0.05	4.3		13.1 ug/L /// 1.3 lbs/day	33	3.07	11.206	

of ex.

no exceptions

no exceptions due to all concentrations being below 100ug/L